



AQUA PRO-TECH LABORATORIES  
 Certified Environmental Testing

Client: Saint Josephs School for the Blind  
 761 Summit Ave  
 Jersey City, NJ 07307

APL Order ID Number: 2040873  
 Collected : 04/19/2022 7:30  
 Received: 04/19/2022

Contact:  
 Client Project: SAINT JOSEPHS SCHOOL FOR THE  
 BLIND

Contact: 05/02/2022 10:31  
 Customer Service Rep: DRAFT REPORT

### Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>2040873-01</b>	<b>Drinking Water</b>	<b>KITCHEN</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:48	4/22/22 12:48	0.138			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:48	4/22/22 12:48	< 0.00200	U		0.00200	mg/L
<b>2040873-02</b>	<b>Drinking Water</b>	<b>KITCHEN</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:50	4/22/22 12:50	0.153			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:50	4/22/22 12:50	< 0.00200	U		0.00200	mg/L
<b>2040873-03</b>	<b>Drinking Water</b>	<b>RECEPTION</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:52	4/22/22 12:52	0.189			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:52	4/22/22 12:52	< 0.00200	U		0.00200	mg/L
<b>2040873-04</b>	<b>Drinking Water</b>	<b>EDU CONF</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:55	4/22/22 12:55	0.297			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:55	4/22/22 12:55	< 0.00200	U		0.00200	mg/L
<b>2040873-05</b>	<b>Drinking Water</b>	<b>NURSE</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:57	4/22/22 12:57	0.282			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:57	4/22/22 12:57	< 0.00200	U		0.00200	mg/L

Brian Wood  
 Laboratory Director

## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>2040873-06    Drinking Water    NURSE(BACK RM)</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 12:59	4/22/22 12:59	0.324			0.00200	mg/L
Lead	EPA 200.8	4/22/22 12:59	4/22/22 12:59	< 0.00200	U		0.00200	mg/L
<b>2040873-07    Drinking Water    LUNCH RM</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:02	4/22/22 13:02	0.205			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:02	4/22/22 13:02	< 0.00200	U		0.00200	mg/L
<b>2040873-08    Drinking Water    GYM(FRONT)</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:04	4/22/22 13:04	0.517			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:04	4/22/22 13:04	< 0.00200	U		0.00200	mg/L
<b>2040873-09    Drinking Water    RM 118</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:07	4/22/22 13:07	0.200			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:07	4/22/22 13:07	< 0.00200	U		0.00200	mg/L
<b>2040873-10    Drinking Water    RM 119</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:09	4/22/22 13:09	0.178			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:09	4/22/22 13:09	< 0.00200	U		0.00200	mg/L
<b>2040873-11    Drinking Water    GYM (BACK)</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 14:13	4/22/22 14:13	0.228			0.00200	mg/L
Lead	EPA 200.8	4/22/22 14:13	4/22/22 14:13	< 0.00200	U		0.00200	mg/L
<b>2040873-12    Drinking Water    RM 120</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:18	4/22/22 13:18	0.181			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:18	4/22/22 13:18	< 0.00200	U		0.00200	mg/L
<b>2040873-13    Drinking Water    RM 152</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:21	4/22/22 13:21	0.136			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:21	4/22/22 13:21	< 0.00200	U		0.00200	mg/L
<b>2040873-14    Drinking Water    RM 121</b>								

Brian Wood  
Laboratory Director



## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>2040873-14</b>	<b>Drinking Water</b>	<b>RM 121</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:23	4/22/22 13:23	0.140			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:23	4/22/22 13:23	< 0.00200	U		0.00200	mg/L
<b>2040873-15</b>	<b>Drinking Water</b>	<b>RM 122</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:26	4/22/22 13:26	0.123			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:26	4/22/22 13:26	< 0.00200	U		0.00200	mg/L
<b>2040873-16</b>	<b>Drinking Water</b>	<b>RM 123</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:28	4/22/22 13:28	0.138			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:28	4/22/22 13:28	< 0.00200	U		0.00200	mg/L
<b>2040873-17</b>	<b>Drinking Water</b>	<b>RM 125</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:30	4/22/22 13:30	0.143			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:30	4/22/22 13:30	< 0.00200	U		0.00200	mg/L
<b>2040873-18</b>	<b>Drinking Water</b>	<b>RM 129</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:33	4/22/22 13:33	0.208			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:33	4/22/22 13:33	< 0.00200	U		0.00200	mg/L
<b>2040873-19</b>	<b>Drinking Water</b>	<b>RM 130</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:35	4/22/22 13:35	0.158			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:35	4/22/22 13:35	< 0.00200	U		0.00200	mg/L
<b>2040873-20</b>	<b>Drinking Water</b>	<b>RM 131</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:37	4/22/22 13:37	0.132			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:37	4/22/22 13:37	0.0188			0.00200	mg/L
<b>2040873-21</b>	<b>Drinking Water</b>	<b>RM 132</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:44	4/22/22 13:44	0.200			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:44	4/22/22 13:44	0.00886			0.00200	mg/L
<b>2040873-22</b>	<b>Drinking Water</b>	<b>HALLWAY</b>						

Brian Wood  
Laboratory Director



## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>2040873-22</b>	<b>Drinking Water</b>	<b>HALLWAY</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:47	4/22/22 13:47	0.386			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:47	4/22/22 13:47	< 0.00200	U		0.00200	mg/L
<b>2040873-23</b>	<b>Drinking Water</b>	<b>ADMIN OFFICE</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:49	4/22/22 13:49	0.187			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:49	4/22/22 13:49	< 0.00200	U		0.00200	mg/L
<b>2040873-24</b>	<b>Drinking Water</b>	<b>BOARD CONF</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:52	4/22/22 13:52	0.291			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:52	4/22/22 13:52	0.00271			0.00200	mg/L
<b>2040873-25</b>	<b>Drinking Water</b>	<b>RM 235</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:54	4/22/22 13:54	0.135			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:54	4/22/22 13:54	0.00959			0.00200	mg/L
<b>2040873-26</b>	<b>Drinking Water</b>	<b>RM 234</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:56	4/22/22 13:56	0.144			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:56	4/22/22 13:56	< 0.00200	U		0.00200	mg/L
<b>2040873-27</b>	<b>Drinking Water</b>	<b>RM 233</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 13:59	4/22/22 13:59	0.199			0.00200	mg/L
Lead	EPA 200.8	4/22/22 13:59	4/22/22 13:59	< 0.00200	U		0.00200	mg/L
<b>2040873-28</b>	<b>Drinking Water</b>	<b>RM 232</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 14:01	4/22/22 14:01	0.171			0.00200	mg/L
Lead	EPA 200.8	4/22/22 14:01	4/22/22 14:01	0.00225			0.00200	mg/L
<b>2040873-29</b>	<b>Drinking Water</b>	<b>RM 231</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 14:03	4/22/22 14:03	0.164			0.00200	mg/L
Lead	EPA 200.8	4/22/22 14:03	4/22/22 14:03	< 0.00200	U		0.00200	mg/L
<b>2040873-30</b>	<b>Drinking Water</b>	<b>RM 230</b>						

Brian Wood  
Laboratory Director



## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>2040873-30    Drinking Water    RM 230</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/22/22 14:06	4/22/22 14:06	0.166			0.00200	mg/L
Lead	EPA 200.8	4/22/22 14:06	4/22/22 14:06	0.00651			0.00200	mg/L
<b>2040873-31    Drinking Water    RM 229</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/26/22 20:02	4/26/22 20:02	0.183			0.00200	mg/L
Lead	EPA 200.8	4/26/22 20:02	4/26/22 20:02	< 0.00200	U		0.00200	mg/L
<b>2040873-32    Drinking Water    2ND FL HALLWAY</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/26/22 20:04	4/26/22 20:04	0.154			0.00200	mg/L
Lead	EPA 200.8	4/26/22 20:04	4/26/22 20:04	< 0.00200	U		0.00200	mg/L
<b>2040873-33    Drinking Water    RM 214</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/26/22 20:07	4/26/22 20:07	0.132			0.00200	mg/L
Lead	EPA 200.8	4/26/22 20:07	4/26/22 20:07	< 0.00200	U		0.00200	mg/L
<b>2040873-34    Drinking Water    RM 201</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	4/26/22 20:14	4/26/22 20:14	0.186			0.00200	mg/L
Lead	EPA 200.8	4/26/22 20:14	4/26/22 20:14	< 0.00200	U		0.00200	mg/L

**FootNotes**

RL - Reporting limit  
 MDL - Minimum detection limit  
 ND, U - Indicates compound analyzed for but not detected  
 J - Indicates estimated value

B - Indicates compound found in associated blank  
 E - Concentration exceeds highest calibration standard  
 D - Indicates result is based on a dilution  
 P - Greater than 25% diff. between 2 GC columns  
 H - Indicates a Hold Time violation  
 D1 - Sample was Decanted (Dissolved)

Brian Wood  
 Laboratory Director





AQUA PRO-TECH LABORATORIES  
 Certified Environmental Testing

Client: St. Joseph's School for the Blind  
 761 Summit Ave  
 Jersey City, NJ 07307

APL Order ID Number: 2061020  
 Collected : 06/21/2022 7:30  
 Received: 06/21/2022

Contact:  
 Client Project: St. Josephs School for the Blind

Contact: 07/06/2022 12:48  
 Customer Service Rep: Tony Tudda

### Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
--------------------------	--------	----------	----------	--------	------	-----	----	-------

**2061020-01 Drinking Water Rm 131**

**Total Metals**

Copper	EPA 200.8	6/30/22 18:34	6/30/22 18:34	0.0176			0.00200	mg/L
Lead	EPA 200.8	6/30/22 18:34	6/30/22 18:34	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit  
 MDL - Minimum detection limit  
 ND, U - Indicates compound analyzed for but not detected  
 J - Indicates estimated value

B - Indicates compound found in associated blank  
 E - Concentration exceeds highest calibration standard  
 D - Indicates result is based on a dilution  
 P - Greater than 25% diff. between 2 GC columns  
 H - Indicates a Hold Time violation  
 D1 - Sample was Decanted (Dissolved)

Brian Wood  
 Laboratory Director